



COMPANY: _____
 CONTACT: Joey Elaty
 PHONE: _____
 LOCATION: Conway TX
35.1932, -101.38909
 OWNER: _____

DATE: 2-15
 TIME IN: 8:00 TIME OUT: 3:00

PUMP MOTOR:		PRESSURE TANK:	
HP	<u>1</u>	GAL	<u>44</u>
V	<u>230</u>	MAKE	<u>Well X</u>
PHASE	<u>1</u>	PSI	<u>13</u>
MAKE	<u>—</u>	DATE	<u>—</u>

NOTES:

-Vault Repair
-Steel Seal
-1" Union

CONTROL BOX:		CONTROL TEST	
HP	<u>1</u>	AMP	
V	<u>230</u>	RED	<u>38</u>
PHASE	<u>1</u>	YELLOW	<u>32</u>
MAKE	<u>Centri</u>	BLACK	<u>5</u>

ELECTRIC: _____

	OHM
R/Y	<u>11.8</u>
B/Y	<u>3.5</u>

WELL HEAD:		WELL INFO:	
CASING SIZE	<u>4"</u>	DEPTH	<u>310</u>
MATERIAL	<u>Steel</u>	STATIC PUMP DEPTH	<u>225</u>
CAP/SEAL	<u>Seal</u>		<u>300</u>
DISCHARGE	<u>1"</u>		

TEST PUMP:		PRESSURE SWITCH:	
GPM	<u>5</u>	WITHIN 10' OF TANK	<u>✓</u>
PSI	<u>20</u>	PSI RATING	<u>30/50</u>
DURATION	<u>2hr</u>		

RECOMMENDATIONS:

Drill 5" well

THE INFORMATION STATED ABOVE IS NO GUARANTEE OF FUTURE PEROFMANCE OR VIABILITY